


NATIONAL INSTITUTE OF TECHNOLOGY TIRUCHIRAPPALLI – 15

Web : www.nitt.edu

mail: thambi@nitt.edu

Phone : 0431 –250 3840

ESTATE MAINTENANCE DEPARTMENT/ELECTRICAL



TENDER DOCUMENT (TECHNICAL BID)

Name of work	:	Electrical renovation work of smart class room at DEE and workshop, providing UPS wiring at calibration lab, lighting to solar passive building and street lights to department entrance in CEESAT dept.
Value of Work	:	₹ 9,85,782/-
Tender Enquiry No	:	18/16-17
Period of Contract	:	3 Months
Tender Enquiry No	:	<u>NITTEO/EMD/EE(E)/AE (P&D)/Enq.No:18/16-17</u>

NATIONAL INSTITUTE OF TECHNOLOGY
TIRUCHIRAPALLI -620 015.
ESTATE MAINTENANCE DEPARTMENT/ELECTRICAL

NOTICE INVITING TENDER

1. **Name of Work** : **Electrical renovation work of smart class room at DEE and workshop and providing UPS wiring at calibration lab, lighting to solar passive building and street lights to department entrance in CEESAT dept.**
2. **Estimated Cost** : **₹ 9,85,782/-**
3. **Earnest Money Deposit** : **₹ 19,716 /-**
4. **Completion time** : **3 Months** (from the date of commencement of work which will be reckoned from the date of agreement with the contractor)
3. **Cost of tender document** : **₹ 525/-**
4. **Last Date & Time for downloading of tenders:** : **12.08.2016 & 3.00 P.M**
5. (a) **Date & Time of Tender opening (Technical Bid):** **12.08.2016 & 3.30 P.M**
(b) **Opening of Price bid :** **only qualified bids after evaluation with intimation.**
6. **Maintenance period and handing** : **6 (Six months from the date of actual completion of entire work and hand over to National Institute of Technology)**
7. **Address for Submission of tender** : **The Director, National Institute of Technology, Tiruchirappalli-620 015.**

Tender document contains 32 pages including Price bid.

Name of the Agency Submitting :

the tender

.....

.....

.....

Check list to evaluate the capability of the tenderer qualifying for price bid opening.

Sl. No	Item/ Requirement from the Bidder	Bidders Response should be definite, complete and legible. Use separate sheet wherever necessary.
1	Particulars of remittance of EMD: Specify (a) DD Number (b) Amount (c) Name of Issuing Banker Note: Bids without EMD will be rejected summarily	
2	Particulars of remittance of Cost of Tender Document. Specify (a) DD Number (b) Amount (c) Name of Issuing Banker Note: Bids without cost of tender document will be rejected summarily.	
3	Name and Complete Postal address of the Applicant or Bidder Firm/ Company with phone/ Fax/ Mobile number	
4	Legal status / Constitution of the Bidder : (a) Sole Proprietor (b) Partnership (c) Private Limited Company (d) Public Limited Company (e) others Please attach self-attested documentary proof	
5	Details of A Grade License obtained from the Licensing Authority (Attach Self attested Xerox Copy)	
6	Nature of the Business of the Bidder	
7	Year of Commencement of Business	
8	Location of the Registered / Main Office	
9	(a) Name, (b) address ,(c) designation, (d) phone & cell number and (e) E mail ID of the CONTACT PERSON of the applicant/ bidder	
10	Name and address of your banker	
11	Copy of Income Tax Permanent Account Number (PAN Number) (Please Attach self-attested Xerox copy)	
12	Annual Turnover during the Last three financial years 2013-14,2014-15 & 2015-16 (Profit and Loss Account and Balance sheet duly audited and certified by a Chartered Accountant and Income Tax Return Acknowledgement i.e., ITR for the last three years may be attached)	

13	Details of Manpower available with the bidder	Use separate sheet to furnish the list
14	Details of Equipment/ Tools/ Tackles available with bidder	Use separate sheet to furnish the list
15	Registration with Employees Provident Fund (furnish documentary proof)	
16	Registration with Employees State Insurance (furnish documentary proof)	
17	Service Tax Registration Number, (Self attested Xerox copy to be attached)	
18	Details of similar work, if any, executed or being executed along with address of the service receiver with contact number, value of the work. Enclose a copy of the work order along with performance certification.	Use separate sheet to furnish complete details in Appendix-B format.

- ✓ I / we hereby certify that all the statements made and information supplied in the enclosed forms and accompanying statements are true and correct.
- ✓ I / we have furnished all information and details necessary for deciding our eligibility to be qualified for taking part in the tendering process for the work. We have no further information to supply.
- ✓ I/We also authorize the Director, NIT Tiruchirappalli or his representative to approach individuals, firms and corporations to verify our competence and general reputation.

Authorized signatory of Bidder with Seal

Name.....

Designation.....

ESTATE MAINTENANCE DEPARTMENT/ELECTRICAL

INSTRUCTION TO TENDERERS

- 1) The tender value includes cost of Electrical and civil materials and all other related material required for completion of the work.
- 2) Time is the essence of the contract. Being a time bound project, the contractor should make all efforts to complete the work in time.
- 3) Even though the overall completion period is indicated as 3 **months**, the work shall be completed progressively and handed over as per agreed split up schedule if any.
- 4) The tenderers are advised to visit the site and get themselves acquainted with the site conditions before submitting the offer.
- 5) Tender quantity is only approximate and liable for variation without entitling the tenderer to any compensation, till the total value of contract vary by more than 30% (thirty percentage).
- 6) Quoted rate shall remain valid for a period of 90 days from the date of tender opening for the release of work order and will be firm throughout the contract period of **3 months** or till completion of work, once awarded and no cost escalation is allowed on any account.
- 7) The item rate offered is for finished item of works and shall provide for the complete cost towards fuel, tools, tackles, plant & machinery, temporary works, labour, materials, levies, taxes, transport, lay-out, repairs, rectifications, maintenance till handing over, supervision, labour colonies, establishment, services, roads, revenue expenses, overheads, profits & all other incidentals etc., complete. Rate quoted shall include all royalties, terminal taxes, Octroi duties, Central or Provincial Excise Tax, Sales Tax and any other taxes leviable under the State or Central Government rules. NITT will not entertain any claim whatever in this respect. **The applicable Service Tax can be reimbursed by NITT along with the running / final bill on production of documentary evidence by the agency for having paid the service tax to the authorities concerned.**
- 8) Some changes are likely in the quantities furnished as well as in the layout, design and specifications of the work. The rates quoted shall be deemed to be inclusive of all such contingencies
- 9) The work shall be carried out as per drawings released then and there, Electricity act 2003 and its amendments BIS/CPWD specifications, standard code of practice and as per the instructions of Engineer-in-charge. The brief description of items of work is given in the bill of quantities. **Tenderer has to quote rates both in figures and in words for all the items given in the Bill of Quantities provided in the Price Bid.**

- 10) For any item of work not covered in Bill of Quantities, the rate will be arrived at based on the procedure given in CPWD manual.
- 11) Since the responsibility for the quality, workmanship and accuracy of any work being carried out under this contract lies with the contractor, the contractor should ensure that no work is done without the presence of contractor's representative at the work spot, whose strength depends on the value of contract awarded. The contract should arrange for surveying construction site at his own cost.
- 12) The decision of Engineer-in-charge shall be final and binding on the contractor regarding clarification of items in this tender schedule.
- 13) The works contract to be entered into with the successful tenderer will be governed by the CPWD Works Manual in force.
- 14) The contractor shall strictly adhere to various labour laws in force.
- 15) To safeguard the persons working at height in roof, wall etc., sufficient number of Industrial Safety nets shall be provided at tenderer's cost in appropriate level and locations. The working hand including Supervisors, Engineers should wear the personal protective items and safety measures such as helmets, safety belts, shoes, etc., before entering into working place.
- 16) The tenderer has to deploy adequate labour of required categories such as Electrician, Wireman, Foreman, Supervisor, Technically experienced, etc. so as to execute the works simultaneously in all areas of work.
- 17) Expertise labour and work experienced persons only to be engaged for specialized items of work like laying of cables, erection of transformer, DGs, HT & LT panels, cable terminations and cable joint kit etc.
- 18) The contractor shall follow norms of NITT security system for movement of men & materials within the campus.
- 19) All the works shall be executed as per the standard specifications as provided in CPWD / BIS/Electricity act 2003 and its amendment.
- 20) All the materials to be used in the work and the nature of work shall conform to the respective CPWD & BIS and National Building Organisation, Standard Specifications forming part of "DELHI STANDARD SCHEDULE OF RATES" specifications and shall be got approved by the Engineer-in-charge before actual incorporation in the work.
- 21) All materials brought by the Contractor for incorporation in the work shall be got inspected and approved by the Engineer-in-charge before they are incorporated in the work and submitted with bills.

- 22) All safety measures are to be followed during execution of work, particularly during blasting and only licensed blaster should be engaged for this purpose. Sufficient care shall be taken by the contractor during excavation to avoid damages to the buried pipe lines, cables and other infrastructure if any etc. Controlled blasting including muffling can be carried out with prior permission from safety department. Damages caused if any shall be rectified at contractor's risk and cost.
- 23) The contractor should extend fullest co-operation with the third party agencies engaged, if any by NITT, to adhere the Quality Control Procedures ensuring quality.
- 24) The contractor should extend full co-operation to the other contractors who may be doing other works in the same areas to enable them to execute their portions of work without any delay or difficulty.
- 25) Tenderers are requested to furnish the duly filled in payment format attached as separate sheet along with a cancelled cheque leaf to accept Electronic fund transfer / R T G S transfer for any payment from NITT, Trichy.
- 26) No advance / mobilization advance will be given.
- 27) LD / Penalty clause is applicable as per CPWD Works Manual in force.
- 28) NITT reserves its right to reject a tender due to unsatisfactory past performance in the execution of a contract awarded against a different Tender.
- 29) The tenderer has to ensure payment of Minimum Wages as per Central rules and Minimum Wages as applicable under law from time to time.
- 30) Also the labourers shall be paid a minimum bonus which shall be 8.33% as per the payment of Bonus Act 1965 for the total wages paid.
- 31) The Contractor shall have to remit EPF & ESI contributions at the rates applicable under law to the authorities concerned for the total wages paid / abide by BOCW Act / Coverage in Group Insurance Scheme / All Risk Policy.
- 32) Rate for each item should be quoted in FIGURES and in WORDS. In case of any difference in the rates quoted in figures and in words, the lower of the two rates will be taken as the tendered rate. Unit rate quoted shall be the basis for arriving the total value of the tender. The total amount for every item shall be arrived by multiplying the unit rate with the quantity indicated for that item. In case of any arithmetic deviation is noticed in the total amount, the same will be corrected and evaluated by taking unit rate as basis and multiplying with the quantity indicated.
- 33) Tenders received after the due date and time of opening, will not be accepted.
- 34) The contractor's responsibility under this contract shall commence from the date of receipt of the LOI by the tenderer. The scheduled period of completion for this work is as mentioned in page No. 01, and the Contractor will have to plan his work accordingly.
- 35) Generally, the maintenance period for any work under NITT will be SIX (6) MONTHS from the date of completion.

- 36) All the documents shall be duly signed with seal in all pages and placed in a common sealed cover duly superscripting the **Name of Work, Tender reference & Date of opening** and submitted.
- 37) Tenderer should furnish the RATE in the enclosed tender “Price Bid” and shall be duly signed with seal in all pages and placed in a separate sealed cover duly superscripting the cover “PRICE BID”.
- 38) The Demand Draft towards Document cost & EMD along with complete tender document consisting Technical qualification details but excluding price bid shall be placed in a separate cover duly superscripting the cover “Technical Bid”. Tender without EMD or document cost will be rejected.
- 39) Totally there will be 2 Separate sealed covers. One cover containing Document cost, EMD and the tender documents containing Technical Qualifications and the other containing the “Price Bid” both the contents duly signed with seal in all pages.
- 40) Both the above 2 Covers shall be placed in a Common Sealed Cover and submitted before the said due date as given above superscripting the tender No. & Date and Due Date.
- 41) Any deviation to this tender terms & condition and schedules of this tender will cause total rejection of the offer submitted
- 42) Incomplete offers will become liable for rejection.
- 43) Tender addressed to **The Director, NIT, Tiruchirappalli-620 015** will be received up to 15.00 Hrs **at the office of the Registrar** as per the schedule of tender notice and will be opened at 15.30 Hrs in the presence of those who may choose to attend the tender opening.
- 44) Tender submitted by post should be sent superscripting “**Register Post with Acknowledgement Due**”. These should be posted with due allowance for any postal delay. Tender received after due date and time of opening tenders, will be rejected and NIT, Trichy will not be responsible for any postal delay or tender may be put into tender box.
- 45) **Earnest Money Deposit:**
Earnest Money is to be paid by each tenderer to ensure that the tenderer does not refuse to execute the work after it is awarded to him. Shall also be furnished in the form of **Demand Draft** in favour of The Director, NIT Tiruchirappalli. EMD in any other form will not be accepted. The rate of earnest money deposit shall be as under:
- | | |
|-----------------------------------|--|
| Works costing upto Rs. 1 lakh | 1% |
| Works costing more than Rs.1 lakh | 2% of the Estimated cost put to tender |
- EMD by the Tenderer will be forfeited if,

- a) After opening the tender, the tenderer revokes his tender within the validity period or increases his earlier quoted rates.
- b) The tenderer does not commence the work within the period as per LOI / Contract. In case the LOI / contract is silent in this regard then within 15 days after award of contract.
- c) EMD given by all unsuccessful tenderers shall be refunded normally within fifteen days of acceptance of award of work by the successful tenderer.
- d) EMD shall not carry any interest.

47. **Security Deposit on estimate cost/Tender Value**

- I. Security Deposit should be collected from the successful tenderer in the **form of DD or Bank Guarantee**. The rate of Security Deposit will be as below:

Up to Rs. 10 lakhs	10%
Above Rs. 10 lakhs up to Rs.50 lakhs	Rs.1 lakh + 7.5% of the amount exceeding Rs. 10 lakhs.
Above Rs. 50 lakhs	Rs.4 lakhs + 5% of the amount exceeding Rs. 50 lakhs.

The security Deposit should be collected before start of the work from the contractor.

- II. Only pay order or Demand Draft in favor of The Director, NIT, Tiruchirappalli is accepted towards Security Deposit.
- III. Security deposit can also be recovered at the rate of 10% from the running bills. However in such cases at least 50% of the Security Deposit should be deposited before start of the work and the balance 50% may be recovered from the running bills.
- IV. EMD of the successful tenderer shall be converted and adjusted against the security deposit.
- V. The security deposit shall not carry any interest.

Unless the contractor whose tender is accepted signs the Contract Agreements and makes the necessary security deposit specified in Para 47 above within Seven days of the date of the order directing him to do so, the amount of Earnest Money Deposit already deposited by him will be forfeited and acceptance of his tender withdrawn.

- 48. National Institute of Technology will not be bound by any power of attorney granted by the tenderer or by changes in the composition of firm made subsequent to the execution of the contract. They may however recognize such power of attorney and changes after obtaining proper legal advice, the cost of which will be chargeable to the contract concerned.
- 49. If the tenderer deliberately gives wrong information in his tender or creates conditions favourable for the acceptance of his tender, NITT reserves the right to reject such tender at any stage.
- 50. The expenses for completing and stamping the agreement shall be paid by the contractor.

51. Tenderers shall not increase their quoted rate in case NITT, negotiates for reduction of rate. Such negotiation shall not amount to cancellation or withdrawal of the original offer and the rate originally quoted shall be binding on the tenderers for a period of three months from the date of opening of tenders.
52. Canvassing in any form in connection with tenders is strictly prohibited and the tenders submitted by the contractors who resort to canvassing will be liable to rejection
53. All entries in the tender documents should be in one ink. Erasers and over writings are not permitted. All cancellations and insertions should be duly attested by the tenderer concerned.
54. TENDERERS should fill in all the required particulars in the blank spaces provided for this purpose in the tender documents and also sign each and every page of Tender Documents including the drawings attached there to, before submitting their tender.
55. Conditional and Un witnessed tenders, tender containing absurd rates and amounts tenders which are incomplete or otherwise considered defective and tenders not in accordance with the tender conditions laid down by the Accepting Officer are liable to be rejected.
56. Tenders not submitted on the prescribed form are liable to be rejected.
57. This tender notice shall be deemed to form an integral part of the contract to be entered into for this work.
58. The tenderers are advised to go through the condition stipulated in Tender document & code of conduct for 'Safety of Contract Labourer' in details. Any violation thereof will invite punitive action being taken against them. While quoting the rate all the above factors are to be taken into account.
- 59. Agency registered with NSIC is exempted from payment of tender document cost & Earnest Money Deposit but required to attach the attested copy of registration indicating the company name, address, registration number, validity & product for which registered in the technical bid,. Any deviation in the certificate on product or validity or name of the company tendering, will attract rejection resulting non-opening of respective price bid.**
60. Compensation for Delay:

If the contractor fails to maintain the required progress or to complete the work and clear the site on or before the contracted or extended period of completion, he shall, without prejudice to any other right or remedy of the NITT on account of such breach, pay as agreed compensation an amount calculated as stipulated below or such smaller amount as may be fixed by the NITT on the contract value of the work for every week that the progress remains below or that the work remains incomplete. This will also apply to items or group of items for which separate period of completion has been specified.

For this purpose the term 'Contract Value' shall be the value at contract rates of the work as ordered and the compensation for delay is by way of recovery at 1 percent of contract value per week of delay provided always that the total amount of compensation for delay to be paid under this condition shall not exceed 10% of the contract value or of the contract value of the item or group of items of work for which a separate period of completion is given.

The amount of compensation may be adjusted or set-off against any sum payable to the Contractor under this or any other contract with the NITT.

61. Arbitration:

Except where otherwise provided for in the contract all questions and disputes relating to the meaning of the specifications, designs, drawings and instructions hereinbefore mentioned and as to the quality of workmanship or materials used on the work or as to any other question, claim, right, matter or thing whatsoever in any way arising out of or relating to the contract, designs, drawings, specifications, estimates, instructions, orders or these conditions or otherwise concerning the work or failure to execute the

same whether arising during the progress of the work or after the completion or abandonment thereof shall be referred to the sole arbitration of the Director of NITT and if Director is unable or unwilling to act, to the sole arbitration of some other person appointed by the Director, willing to act as such arbitrator. The cases referred to arbitration shall be other than those for which the decision of the Estate Officer / Engineer-in-charge is expressed in the contract to be final and conclusive. There will be no objection if the arbitrator so appointed is an employee of NITT and that he had to deal with the matters to which the contract relates and that in the course of his duties as such he had expressed views on all or any of the matters in dispute or difference.

The arbitrator to whom the matter is originally referred being transferred or vacating his office or being unable to act for any reason, Director as aforesaid at the time of such transfer, vacation of office or inability to act, shall appoint another person to act as arbitrator in accordance with the terms of the contract. Such person shall be entitled to proceed with the reference from the stage at which it was left by his predecessor. Subject as aforesaid the provision of the Arbitration & Reconciliation Act, 1996 or any statutory modification or re-enactment thereof and the rules made there under and for the time being in force shall apply to the arbitration proceeding under this clause.

It is a term of the contract that the party involving arbitration shall specify the dispute or disputes to be referred to arbitration under this clause together with the amount or amounts claimed in respect of each such dispute.

The arbitrator(s) may from time to time with consent of the parties enlarge the time for making and publishing the award.

The work under the Contract shall, if reasonably possible, continue, during the arbitration proceedings and no payment due or payable, to the Contractor shall be withheld on account of such proceeding.

The Arbitrator shall be deemed to have entered on the reference on the date he issues notice to both the Parties fixing the date of first hearings. The arbitrator shall give a separate award in respect of each dispute or difference referred to him. The venue of arbitration shall be such place as may be fixed by the Arbitrator in his sole discretion. The award of the arbitrator shall be final, conclusive and binding on all parties to this contract.

In the event of disputes or differences arising between one public sector enterprise and a Govt. Department or between two public sector enterprises the above stipulations shall not apply or its amendments for arbitration shall be applicable.

62. **Force Majeure clause:** If at any time during the continuance of this contract the performance in whole or in part by either party of any obligations under this contract shall be prevented or delayed by reason, of any war, hostilities, acts of the public enemy, civil commotion, sabotage, fires, explosions, epidemics, quarantine, restrictions or acts of GOD (hereinafter referred to as events) then provided notice of happening of any such events is given by either party to other within twenty one days from the date of occurrence thereof neither party shall reason of such events be entitled to terminate this contract nor shall either party have any such non-performance and delay is resumed as soon as practicable after such events has come to an end or ceased to exist. If the performance in whole or part of any obligation under this contract is prevented or delayed by reason or any such event claims for extension of time shall be granted for period considered reasonable by NITT subject

to prompt notification by the tenderer to NITT of the particulars of the events and supply to the NITT if required of any supporting evidence. Any waiver of time in respect of partial installment shall not be deemed to be a waiver of time in respect of remaining deliveries.

The correspondence exchanged against the tender from both tenderer and NITT through email are considered as valid document legally though it is not signed. It is treated as valid confirmations made on behalf of the respective company and very much comes under the legal ambit of the business transaction and hence it is binding on both the parties to the business.

Any transaction pertaining to the tender from both the parties of business done round the clock irrespective of the office or business hours of the companies, are valid legally and binding on both the parties. This applies to the extent only in such cases where deadline time for transaction is not specifically declared by either or both the parties to the business.

In case Letter of Intent (LOI) is issued through email, the PC generated time and date of mail shall be construed as the official time and date of release of LOI. In as much as this date is within the last date of validity given by the tenderer the LOI is said to have been issued within the validity period and shall be binding on both the parties to the business.

Tenderers participating in the tender should declare in their technical bid that whether they have been black-listed / kept on hold for a specified period / given Business holiday for a specified period by any Public sector undertaking or Government departments. The reasons for such action with details and the current status of such hold shall be clearly furnished to NITT. If no such details are mentioned in the offer then it will be construed that the subject tenderer is not under any such hold. But at a later date if it comes to the notice of NITT about any such hold under enforcement on the subject tenderer, NITT will have every right to reject the offer of such vendors at any point of time and also under any stage of the finalization of the subject tender irrespective of the status of the subject tenderer in that tender. Such tenderers will not be permitted to participate in the further tender proceedings and will be communicated suitably. They will not be also considered for any ongoing tenders even if participated till the hold is officially lifted and confirmed in writing.

GENERAL CONDITIONS OF CONTRACT

1. No night work will be permitted without the written permission of the Engineer – in – charge.
2. Items of work other than those mentioned in the Bill of Quantities (Tender Schedule) attached hereto will be carried out at the rates to be fixed by this organization as per relevant clauses of CPWD Works Manual.
3. Permission for erection of temporary work sheds etc., at site will have to be obtained from NITT in writing in advance.
4. The works contract to be entered into with the successful tenderer will be governed by the CPWD works Manual 2012 or the latest in force.
5. The successful tenderer / Contractor shall observe all safety regulations and take necessary safety precaution as called for and Safety Precautions enclosed herewith.
6. In all matters of dispute, the decision of the Director, National Institute of Technology, Tiruchirappalli -620 015. shall be final and binding on the tenderer / contractor.
7. Some changes are likely in the quantities furnished as well as in the layout, design and specifications of the work. The rate quoted shall be deemed to be inclusive of all such contingencies.
8. All the materials to be used in the work and nature of work shall conform to respective Electricity act 2003 and its amendment, CPWD, BIS and National Buildings Organization Standard Specifications and shall be got approved by the Engineer – in – charge before actual incorporation in the work.
9. All materials brought by the Contractor for incorporation in the work shall be got inspected and approved by the Engineer-in-charge before they are incorporated in the work

10. Engineer in charge / Electrical or his duly authorized representative shall have all reasonable times access to Contractor's premises of work and shall have the power at all the reasonable times to inspect and test any portion of the work or examine the materials and workmanship of the structures during their manufacture and test. The contractor shall give due notice in writing to the Inspecting Engineer of NITT when the materials supplied to be incorporated in the work are ready for Inspection and test. No material shall be incorporated in the work until the inspecting Engineer certified in writing that such materials have been inspected and approved by him or else the rejected material should be removed from site immediately.
11. The Contractor shall closely scrutinize all the drawings issued in connection with the work by this organization and bring to the notice of the Engineer-in-charge if any discrepancies, omissions in the drawings before undertaking the actual work pertaining thereto.
12. The contractor should submit in advance every fortnight a detailed programme of work to be undertaken from time to time strictly in conformities with the "Time and Progress Chart" covering the entire constructed work and reschedule them wherever necessary during the progress of the work so as to achieve the target set.
13. The contractor should extend full co-operation to the other contractors who may be doing other works in the same areas to enable them to execute their portions of work without any delay or difficulty.

GENERAL SAFETY PRECAUTIONS TO BE FOLLOWED AT WORK SITE DURING EXECUTION

The following safety measures should be strictly adhered to, during execution of works at sites.

1. Providing the working platform with toe board and handrail for continuous working at heights.
2. Providing safety belt and life line at all times for men working at heights.
3. Providing dust or fume respirator in places where dust and fume concentration exists.
4. Providing goggles and welding screens.
5. Providing acid and alkali proof rubber gloves for handling acid and alkali and chemical which are corrosive.
6. Providing rubber gloves for working on electrical works.
7. Ensuring proper lashing of the components while being transported in vehicles.
8. The vehicles must have side supports or have body to support the materials conveyed.
9. The materials should not be allowed to extend or overflow the sides of the vehicles.
10. Materials should not be allowed to overhang from the rear edge of the body of the vehicle.
11. Driver of the vehicle must possess license.
12. Vehicle must not be overloaded prescribed limits.
13. Red flags and lights for parts projecting from the body of vehicle must be provided.
14. The speed restrictions within the Institute must be strictly adhered to.

15. The gas cylinders must be always handled on trolleys or kept tied down not in use. They should never be rolled as Roller for conveying.
16. Cylinders should not be used without regulators.
17. All excavations must be barricaded and red lamps must be provided.
18. All electrical connections must be properly earthed.
19. Providing helmet, safety belt, etc., for high level work and sufficient number of Industrial Safety nets at appropriate level to safeguard the persons working at high level particularly in roofing etc.,
20. All personal protective equipment conform with standard specification and Contractor including their sub-contractors, agents and labour engaged on the work are required to scrupulously adhere to the safety regulations, safety precautions and measures. Any violation thereof will invite punitive action being taken against them. Also contractors with frequent violations of safety regulations will not be entrusted with further work in this organization.

SAFETY PRECAUTIONS TO BE OBSERVED WHILE TRANSPORTING MATERIALS

I. VEHICLE

1. Vehicles carrying material should have proper registration documents and must be produced on demand by our Security Staff.
2. The light on right side, i.e., over the drivers cabin shall be in working condition.
3. Both the head lights as well as park lamps must be in working conditions.

II. MOVEMENT OF VEHICLE

1. The vehicle should not travel at more than 20 km.ph in our premises.
2. The Driver of the vehicle must possess heavy duty license and produce on demand by the Security Staff.
3. Vehicles carrying inflammable liquids in the tank containers should have grounding chain or the tank should be coated with insulating material also to avoid Static Electricity.
4. In road junctions, speed breakers and railway crossing, the speed should be lowered and vehicle should proceed cautiously.
5. The driving should 'KEEP TO THE LEFT' at all places.
6. The vehicle should not be parked in road which could obstruct the vehicular traffic.
7. No person other than driver should be allowed to sit or stand on the prime mover or trailer.
8. The vehicle should pass only through the approved routes. Short cuts should be forbidden.
9. There must be a safe distance behind another moving truck.
10. The driver should avoid making quick starts, jerky stops or quick turns at excessive speed.

TERMS AND CONDITIONS REGARDING COMPLIANCE WITH VARIOUS LABOUR LAWS BY THE CONTRACTORS FOR NITT

1. The Contractor shall not employ in connection with the work any person who has not completed 18 years of age.
2. The Contractor shall in respect of labour employed by him either directly or through subcontractors, comply with or cause to be complied with the following statutory provisions and rules and in regard to all matters provided therein.
 - a) The Contract Labour (Regulation & Abolition) Act 1970
 - b) The Minimum Wages Act 1948 and related Central Rules.
 - c) The Payment of Wages Act 1936 and related Central Rules.
 - d) The Employee's Provident Fund & Miscellaneous Provisions Act 1952.
 - e) The Employees State Insurance Act 1948.
 - f) The Workmen Compensation Act 1923.
 - g) The Industrial Disputes Act 1947.
 - h) The payment of bonus act 1965and any other law or modifications to the above or to the Rules made thereunder from time to time.
3. The Contractor employing 20 or more workmen is required to obtain license from the authorities (The Deputy Chief Inspector of Factories / Assistant Commissioner of Labour as the case may be). The license shall be amended and / or renewed wherever, there is an increase in the workmen employed by him or in the event of contract being extended or renewed. The Contractor shall inform the license number to the NITT Management before taking up the work.
4. The Contractor (Licensed or unlicensed) shall promptly furnish every information and document required by NITT authorities for the purpose of fulfilling their obligations as Principal Employer and shall render all necessary assistance for the same.

WAGES

5. The Contractor shall pay wages to the workmen employed by him at the rate which shall not be less than the minimum wages applicable under Law from time to time.
6. The Contractor shall fix wage periods in respect of which wages shall be payable. No wage period shall exceed one month.
7. The Contractor shall ensure payment of wages to the contract labour employed by him within three days from the end of wage period in case the wage period is one week or a fortnight and in all other cases before 7th day of the following month.
8. All Payment of wages shall be made on working days at the work site and during the working time and on date notified in advance. In case the work is completed before the expiry of the wage period final payment shall be made within 48 hours of the last working day.

9. Where the employment of any worker is terminated by or on behalf of the Contractor, the wages earned by him shall be paid before the expiry of the second working day from the day on which his employment is terminated.
10. Wages due to every worker shall be paid to him direct or to the person authorized by him in this behalf. All wages shall be paid in current coin or currency in both.

REGISTERS & RECORDS: -

11. The Contractor shall maintain all registers and records in the proper manner and as required by the regulations of the various authorities concerned and indemnify the Employer from the consequences due to any inaccurate or faulty documentation on the part of the Contractor.

POST TECHNICAL AUDIT OF WORK AND BILLS:-

12. NITT reserves the right to carry out the post-payment Audit and technical examination of the work and final bill including all supporting vouchers, abstracts etc., and enforce recovery of any sum becoming due as a result thereof in the manner provided in the presiding sub-paragraphs. Such recovery shall be enforced any time even after passing the final bill.

SUBMISSION OF BILLS BY CONTRACTOR: -

13. The Contractor at the end of each month shall submit a bill in triplicate, if required, detailing the various items of work done during the month supported by the requisitions issued from time to time. The Contractor shall, once in every month, submit to the EO / EMD separately details of his claims for the work done by him up to and including the previous month which are not covered by his contract agreement in any of the following respects:
 - a) Deviation from the items provided in the contract documents.
 - b) Extra items / new items of work.
 - c) Items in-respect of which rates have not been settled. He should in addition furnish a clear certificate to the effect that the claims submitted by him as aforesaid cover all his claims and that no further claims shall be raised by him in respect of the work done up to and including the period under report.

PAYMENT OF BILLS:-

14. All payments to be made to the Contractor, under this contract shall be by NEFT or RTGS within 45 days, after the certification of bills by the execution department.

RECOVERY FROM CONTRACTOR:-

15. Whenever under the contract, any sum of money, shall be recoverable from or payable by the Contractors, the same may be deducted from or any sum then due or which at any time thereafter may become due to Contractor under the contract or under any other contract with NITT or from his Security Deposit or he shall pay the claim on demand.

CANCELLATION OF CONTRACT FOR CORRUPT ACTS:-

16. NITT, whose decision shall be final and conclusive, shall without prejudice to any other right or remedy which shall have accrued shall accrue thereafter to NITT cancel the contract in any of the following cases and the Contractor shall be liable to make payment to NITT for any loss or damage resulting from any such cancellation to the same extent as provided in the case of cancellation for default,

If the Contractor shall:-

- a) Offer or give or agree to give to any person in NITT service any gift or consideration of any kind, as an inducement or reward for doing or for bearing to do or for having done or for borne to do any act, in relation to the obtaining or execution of this or any other contract for NITT service,

OR

- b) Enter in to a contract with NITT in connection with which commission has been paid or agreed to be paid by him or with his knowledge, unless the particulars of any such commission and the terms of payment thereof have previously been disclosed in writing to NITT.

OR

- c) Obtain a contract with NITT as a result of ring tendering or by non-bonafide methods of competitive tendering, without first disclosing the fact in writing to NITT.

CANCELLATION OF CONTRACT FOR INSOLVENCY ASSIGNMENT OF TRANSFER OR SUB-LETTING OF CONTRACT:-

17. NITT, without prejudice to any other right or remedy which shall have accrued or shall accrue thereafter to NITT shall cancel the contract in any of the following cases:

If the Contractor,

- (a) Being an individual or if a firm any partner thereof shall at any time be adjudged bankrupt or have a receiving order for administration of his estate, made against him or shall take any proceedings for liquidation or composition under any bankruptcy Act or assignment of his effects of composition or arrangement for the benefit of his creditors or purport to do so, or if any application made under any Bankruptcy Act for the time being in force for the sequestration of his estate or if a trust deed be granted by him on behalf of his creditors

OR

(b) Being a Company, shall pass a resolution or the Court shall make an order for the liquidation of its affairs, or a receiver or Manager on-behalf of the debenture holders shall be appointed or circumstances shall arise which entitle the Court or debenture holders to appoint a receiver or Manager,

OR

(c) Assigns, Transfers, Sub-lets or attempts to assign, transfer or sub-let any portion of the work without the prior written approval of the NITT.

(d) Whenever NITT exercise the authority to cancel the contract under this conditions, NITT may have the work done by any means at the Contractor's risks and expenses provided always that in the event of the cost of the work so done (as certified by Engineer in charge which is final and conclusive) being less than the contract cost, the advantage shall accrue to the NITT and if the cost exceeds the money due to Contractor under the contract, the Contractor shall either pay the excess amount ordered by Estate Maintenance Dept. or the same shall be recovered from the Contractor by other means.

(e) In case the NITT carries-out the work under the provisions of this condition the cost to be taken into account in determining the excess cost to be charged to the Contractor under this condition shall consist of the cost of the materials, hire charges of tools and plants and/or labour provided by the NITT with an addition of such percentage to cover superintendence and establishment charges as may be decided by Estate Maintenance Dept., whose decision shall be final and conclusive.

CANCELLATION OF CONTRACT IN PART OF FULL FOR CONTRACATOR'S DEFAULT:

18. If the Contractor:

(a) Makes default in carrying out the work as directed and continues in that state after a reasonable notice from Engineer in charge or his authorized representative

(b) Fails to comply with any of the Terms and Conditions of the contract or after reasonable notice in writing with orders properly issued thereunder

(c) NITT, may without prejudice to any other right or remedy which shall have accrued or shall accrue thereafter to NITT, CANCEL the contract as whole or in part thereof or only such work order or items of work in default from the contract. Whenever NITT exercise the authority to cancel the contract as whole or part under this condition NITT may complete the work at the contractor's risk and cost (as certified by Engineer in charge, which is final and conclusive) being less than the contract cost, the advantage shall accrue to the NITT. If the cost exceeds the moneys due to the Contractor under this contract the Contractor shall either pay the excess amount ordered by Estate Maintenance Dept. or the same shall be recovered from the Contractor by other means. In case the NITT carries out the work or any part thereof under the provisions of the conditions the cost to be taken into account in determining the excess cost to be charged to the Contractor under this condition shall consist of the cost of the materials, hire charges of tools and plant and/or labour provided by the NITT with an addition of such percentage to cover the superintendence and establishment charges as may be decided by the Engineer in charge, whose decision shall be final and conclusive.

TERMINATION OF CONTRACT ON DEATH OF CONTRACTOR. :-

19. Without prejudice to any of the rights or remedies under this contract, if the Contractor dies, or if the firm is dissolved or the company is liquidated, NITT shall have the option of terminating the contract without compensation to the Contractor.

SPECIAL POWER TO TERMINATION:-

20. If at any time after the award of contract, NITT shall for any reason whatsoever not require whole or any part of the work to be carried out the Engineer in charge shall give notice in writing of the fact to the Contractor who shall have no claim to any payment of compensation or otherwise howsoever on account of any profit or advantage which he might have derived from the execution of the work in full but which he did not derive in consequence of the fore-closing of the work.

LABOUR:-

21. The Contractor shall remain liable for the payment of all wages or other moneys to his work-people or employees under the payment of Wages Act 1936, Employees Liability Act. 1938, Workmen's Compensation Act 1923 or any other Act or enactment, relating thereto and rules framed, thereunder from time to time.

PRECAUTIONS AGAINST RISK:-

22. The Contractor shall be responsible for providing at his own expense for all precautions to prevent loss or damage from any and all risks and to minimize the amount of any such loss or damage and for the necessary steps to be taken for the said purpose.

23. Rate for additional item / substituted item:

This will be as per the rate analysis based on the market rate for material and labour prevailing at the time of execution at place of work as ascertained by Engineer in charge raised to the overall tender percentage at which the work was awarded to cover overheads / establishment/ profit.

24. Corrigendum / Amendment:

It is tenderer's responsibility to watch for any corrigendum or amendment till the opening of a particular tender, that will be posted only at NITT web site.


NATIONAL INSTITUTE OF TECHNOLOGY TIRUCHIRAPPALLI – 15

Web : www.nitt.edu

mail: thambi@nitt.edu

Phone : 0431 –250 3840

ESTATE MAINTENANCE DEPARTMENT/ELECTRICAL



TENDER DOCUMENT (PRICE BID)

Name of work	:	Electrical renovation work of smart class room at DEE and workshop, providing UPS wiring at calibration lab, lighting to solar passive building and street lights to department entrance in CEESAT dept.
Value of Work	:	₹ 9,85,782/-
Tender Enquiry No	:	18/16-17
Period of Contract	:	3 Months
Tender Enquiry No	:	<u>NITTEO/EMD/EE(E)/AE (P&D)/Enq.No:18/16-17</u>

SCHEDULE 'A'
LIST OF WORKS AND PRICES

NAME OF WORK:

DETAILS & QUANTITIES of each item of work shown in the BILL OF QUANTITIES are only approximate. They are given as a guide for the purpose of tendering only and are liable to variation and alteration of the Competent Authority. The work under each item as executed shall be measured and priced at the corresponding rate quoted by the contractor in the BILL OF QUANTITIES

Sl.No.	Description of work / supplied	Total amount of work (in figures and words)		Period of contract
		Rs.	Ps.	
1. Lakhs (Rupees Lakh and - only) MONTHS	

BILL OF QUANTITIES

Sl. No.	Appx. Qty.	Description of work	TNBP No.	Rate (Both in Unit fig & Words)	Amount	
					Rs.	Ps.

AS PER SEPARATE SHEETS ATTACHED CONTAINING 6 PAGES

FROM SERIAL No. 24 to 32

Contract Agreement No.....

TENDER

To

The Director,
National Institute of Technology
TIRUCHIRAPPALLI –620 015.

I / We hereby offer to carry out the work of

I / We hereby carefully perused the following documents connected with the above noted work and agree to abide by the same.

- 1.Specifications (General & Particular)
- 2.Drawings
- 3.Schedule ‘A’,
- 4.Bill of Quantities
- 5.CPWD works Manual in force.

I / We forward herewith the sum of Rs.....as Earnest Money, which shall be refunded should this tender be rejected. I / We further agree to deposit such sum which along with the sum of Rs.....mentioned above shall make up 50% of the fully Security Deposit for this work as provided for under conditions of the NATIONAL INSTITUTE OF TECHNOLOGY General Conditions of Contract.

I / We further agree to execute all the work referred to in the said documents upon the terms & conditions contained or referred therein and as detailed in Schedule ‘A’ and Bill of Quantities thereto and to carry out such deviations as may be ordered, vide conditions of the NITT upto a maximum of 30% of the tendered amount of Rs.....

I / We further agree to refer all disputes, as required to the sole arbitration of an Officer, to be appointed by the Director, NITT., in his sole discretion whose decision shall be final and binding.

WITNESS

Signature of the Contractor

Date :

1.

2.

SCHEDULE OF WORK

State Tamilnadu Enq.no.18

Branch Electrical

Division EMD

Sub Division EMC

Name of Work : Electrical renovation work of smart class room at DEE and workshop, providing UPS wiring at calibration lab, lightings to solar passive building and street lights to department entrance in CEESAT dept.

ITEM No	SUB-HEADS AND ITEM OF WORK	QUANTITY	UNIT	RATE (Rs)	RATE (In Words)	AMOUNT(Rs)
1	WIRING					
1.1	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with piano type switch, phenolic laminated sheet, suitable size M.S. box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required.					
1.1.1	Group C	6.00	Point			
1.2	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required.					
1.2.1	Group C	26.00	Point			
1.3	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface/ recessed medium class PVC conduit as required					
1.3.1	2 X 4 sq. mm + 1 X 4 sq. mm earth wire	10.00	Metre			
1.4	Rewiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable and 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable as earth wire in existing surface/ recessed steel conduit including dismantling as required.					
1.4.1	Group C	15.00	Point			
1.5	Supplying and fixing metal box of following sizes (nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in front including painting etc as required.					
1.5.1	200 mm X 150 mm X 60 mm deep	2.00	Each			

ITEM No	SUB-HEADS AND ITEM OF WORK	QUANTITY	UNIT	RATE (Rs)	RATE (In Words)	AMOUNT(Rs)
1.5.2	200 mm X 250 mm X 60 mm deep	2.00	Each			
1.6	Supplying and fixing following piano type switch/ socket on the existing switch box/ cover including connections etc. as required.					
1.6.1	5/6 amps switch	10.00	Each			
1.6.2	15/16 amp switch	2.00	Each			
1.6.3	3 pin 5/6 amp socket outlet	10.00	Each			
1.6.4	6 pin 15/16 amp socket outlet	2.00	Each			
1.7	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.					
1.7.1	5/6 amps switch	36.00	Each			
1.7.2	15/16 amp switch	14.00	Each			
1.7.3	3 pin 5/6 amp socket outlet	36.00	Each			
1.7.4	6 pin 15/16 amp socket outlet	14.00	Each			
1.7.5	Blanking plate	10.00	Each			
1.8	Supplying and fixing following Modular base & cover plate on existing modular metal boxes etc. as required.					
1.8.1	6 Module	5.00	Each			
1.8.2	8 Module	20.00	Each			
1.9	DLP plastic Trunking wiring (But the rate without wires) (Make: Legrand/Siemens)					

ITEM No	SUB-HEADS AND ITEM OF WORK	QUANTITY	UNIT	RATE (Rs)	RATE (In Words)	AMOUNT(Rs)
1.9.1	DLP Pastic Trunking 105x50mm and accessories Flexible cover 40mm width-1No, Flexible cover 85mm -1No, Joints for cover 40 mm width-1No, Joints for cover 85mm width-1No, Basejoint-25Nos, Clips-15Nos, Separation partition-1No, Endcap-1No, Internal angles-adjustable from 80 degr - 120 deg - 1No, VDI accessories for internal angles-1No, VDI accessories for external angles -1No, Flat angles -1No, VDI accessories for flat angles-1No, Flat junctions-1No, Flat junctions for specific size-tap off to an 80mm wide branch -1No, VDI accessories for junctions -1No, Wall crossing -1No, Capacity change -1No, Capacity change-1No, partition junction -1No, Cable ties base -1No. (Make: Legrand)	85.00	metre			
1.10	DLP Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FR PVC insulated copper conductor, single core cable in surface/ recessed (The rate without DLP Pastic Trunking) as required.(Make: Finolex)					
1.10.1	2 X 4.0 sq. mm + 1 X 4.0 sq. mm earth wire	155.00	metre			
1.10.2	4 X 4.0 sq. mm + 2 X 4.0 sq. mm earth wire	110.00	metre			
1.10.3	4 X 16.0 sq. mm + 2 X 16.0 sq. mm earth wire	40.00	metre			
1.10.4	4 X 25.0 sq. mm + 2 X 25.0 sq. mm earth wire	65.00	metre			
	Sub-Total					
2	MCCB, MCB & DB'S					
2.1	Providing and fixing following rating and breaking capacity MCCB in existing cubicle panel board including drilling holes in cubicle panel, making connections, etc. as required.					
2.1.1	4 pole 125A, 36 KA	2.00	each			
2.1.2	4 pole 160A, 36KA	2.00	each			
2.2	Supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 volts, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator)					
2.2.1	2 + 8 way, Double door	1.00	Each			

ITEM No	SUB-HEADS AND ITEM OF WORK	QUANTITY	UNIT	RATE (Rs)	RATE (In Words)	AMOUNT(Rs)
2.3	Supplying and fixing following way prewired vertical type TP&N MCB distribution board of steel sheet for 415 volts on surface/ recess complete with loose wire box of sheet steel, dust protected, duly powder painted, inclusive of 200 amps tinned copper bus bar, common neutral link, earth bar, din bar for mounting MCB's, terminal connectors for all incoming and outgoing circuits, duly prewired with adequate size of FRLS PVC insulated copper conductor upto the terminal connector/ neutral link, earthing etc as required (But without MCB/ RCCB/ Isolator). (Note : Prewired vertical type MCB TPDB is normally used where 3 phase outlets are required.)					
2.3.1	8 way Double door	3.00	Each			
2.4	Supplying and fixing 5 amps to 32 amps rating, 240/415 volts, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.					
2.4.1	Single pole	40.00	Each			
2.4.2	Double pole	2.00	Each			
2.4.3	Triple pole	18.00	Each			
2.5	Supplying and fixing single pole blanking plate in the existing MCB DB complete etc. as required.	10.00	Each			
2.6	Supplying and fixing DP sheet steel enclosure on surface/ recess along with 25/32amps 240 volts "C" curve DP MCB complete with connections, testing and commissioning etc. as required.	2.00	Each			
2.7	Supplying and fixing 20 amps, 240 volts, SPN industrial type, socket outlet, with 2 pole and earth, metal enclosed plug top alongwith 20 amps "C" curve, SP, MCB, in sheet steel enclosure, on surface or in recess, with chained metal cover for the socket out let and complete with connections, testing and commissioning etc. as required.	8.00	Each			
2.8	Supplying and fixing FP sheet steel enclosure on surface/ recess along with following amps 415 volts "C" curve FP MCB complete with connections, testing and commissioning etc. as required.					
2.8.1	Four pole MCB 6-32A with enclosure.	9.00	Each			
	Sub-Total					
3	E A R T H I N G					

ITEM No	SUB-HEADS AND ITEM OF WORK	QUANTITY	UNIT	RATE (Rs)	RATE (In Words)	AMOUNT(Rs)
3.1	Supplying and laying 6 SWG G.I. wire at 0.50 metre below ground level for conductor earth electrode, including connection/ termination with GI thimble etc. as required.	25.00	Metre			
3.2	Supplying and fixing cosmos earthing electrode systems.					
3.2.1	COSMOS ROMA 40mm DIA 2 Mtrs LENGTH WITH MOISTURE ENHANCER 25 Kg.	2.00	each			
	Sub-Total					
4	MV CABLE LAYING					
4.1	Laying and fixing of one number PVC insulated and PVC sheathed / XLPE power cable of 1.1 KV grade of following size on wall surface as required.					
4.1.1	Upto 35 sq. mm (clamped with 1mm thick saddle)	15.00	Metre			
4.2	Supply and laying of following size Double walled Corrugated High Density Polyethylene pipe having corrugation on the outer wall and plain surface inner wall conforming to IS 14930 part- I and part -II complete with necessary HDPE fitting for protection of 1.1 KV grade underground cable directly in ground at a depth 75cm including excavation and refilling the trench etc as required.					
4.2.1	Upto 25Sq.mm, Size: 40mm/32mm (OD / ID)	35.00	mtrs			
	Sub-Total					
5	MV CABLE JOINTING & END TERMINATION					
5.1	Supplying and making end termination with brass compression gland and aluminium lugs for following size of PVC insulated and PVC sheathed / XLPE aluminium conductor cable of 1.1 KV grade as required.					
5.1.1	2 X 16 sq. mm (22mm)	2.00	Each			
5.1.2	4 X 16 sq. mm (28mm)	2.00	Each			
5.2	Supplying and making indoor end termination with copper lugs for following size of PVC insulated and PVC sheathed / XLPE copper conductor cable of 1.1 KV grade as required.					
5.2.1	4X16Sq.mm	2.00	each			
5.2.2	4X25Sq.mm	4.00	each			

ITEM No	SUB-HEADS AND ITEM OF WORK	QUANTITY	UNIT	RATE (Rs)	RATE (In Words)	AMOUNT(Rs)
	Sub-Total					
6	CIVIL ITEMS					
6.1	Excavation of the cable trenches in hard rock not exceeding 1.5 metres in width, and lift upto 1.5 metres, including getting out the excavated soil and disposal of excavated soil as directed within a lead of 50 metres.	6.00	Cum			
	Sub-Total					
7	SUPPLY OF POLES					
7.1	Manufacturing, supplying & erection of street light pole made of 80 mm dia C class GI pipe 6 mtr long welded 300mmx 300mmx 10mm thick base plate at bottom and provided with earth stud, Providing 50 mm dia HDPE Pipe/bend for cable entry (to SMC Box) and Wire entry (from SMC Box to Street light pole), painting with one coat of Anti-corrosive Primer and two or more coats of automobile grade metallic paint of approved brand and shade, providing cement concrete foundation (1:3:6) pedestal of size 450 mm x 450mm x 1500 mm , with suitable layer of base concrete below the CC foundation pedestal , Providing 4 Nos 20 mm dia,1500mm long foundation bolt with double nut at top, making hole in the base plate etc as reqd.					
7.1.1	6.00 Mtrs G.I pole	1.00	each			
7.2	Supply of wall brackets.					
7.2.1	Manufacturing, Supply and Installation of Ornamental type MS street light bracket made of approved type and design with 500 mm overhanging from street light pole painting & not less than 9 Kg with one coat of Anti-corrosive Primer and two or more coats of automobile grade metallic paint of approved brand and shade, etc as reqd.	1.00	each			
	Sub-Total					
8	FABRICATION OF CUBICLE BOARDS/LADDER/SOLAR STRUCTURE					
8.1	Panel Boards shifting/dismantling					
8.1.1	Panel Boards shifting and erection charges including channel provision & termination connection etc. as required as required	2.00	each			

ITEM No	SUB-HEADS AND ITEM OF WORK	QUANTITY	UNIT	RATE (Rs)	RATE (In Words)	AMOUNT(Rs)
8.2	Supply of Rubber mats/ fabricated chequered plate/MS plate for following size with bottom support and necessary cutting, grinding, welding, erection including painting and transport charges.					
8.2.1	2mm Class A high voltage 3.3kV (Batch No: 150524) IS15652-2006 insulation mat	2.00	Sq mtr			
	Sub-Total					
9	SUPPLY (MARKET ITEM)					
9.1	Supplying and fixing of ceiling fan of following sweep, suitable for operation on 230 Volts, single phase, 50 Hz, AC Supply including 300 mm long down rod and resistance type regulator as required.(Make: Crompton Greaves, Rivera)					
9.1.1	1200 mm sweep	10.00	Each			
9.2	Supplying of heavy duty 960 RPM exhaust fan of following sweep, suitable for operation on 230 Volts, single phase, 50 Hz, AC Supply including suitable size louvers as required.					
9.2.1	450 mm	4.00	each			
9.3	Supplying and fixing extra conduit down rod					
9.3.1	Supplying and fixing extra conduit down rod of 150 cm length G.I. pipe 20 mm dia, heavy gauge including painting etc. Required. (Note: More than 5 cm length shall be rounded to the nearest 10 cm and 5 cm or less shall be ignored.)	42.00	each			
9.3.2	Clamps for fixing light/Fan fittings	10.00	each			
9.3.3	Supplying and fixing of tube light fitting hook & chain including chipping, fixing & surfacing to make good condition.	8.00	each			
9.4	Supplying and fixing of wall mounting fan of following 450mm sweep, suitable for operation on 230 Volts, single phase, 50 Hz, AC Supply including wall bracket rod and resistance type regulator as required.					
9.4.1	Wall mounting fan (Heavy type) (Make: Crompton Greaves)	6.00	each			
9.5	Repairing and painting works.					
9.5.1	Supply and fixing readymade round cement block including mesh wire ,wall cutting bolt nuts fixing and finishing.	4.00	each			

ITEM No	SUB-HEADS AND ITEM OF WORK	QUANTITY	UNIT	RATE (Rs)	RATE (In Words)	AMOUNT(Rs)
9.6	Supplying and fixing of flexible hose/sleeve as required.					
9.6.1	32mm flexible metal hose	5.00	metre			
	Sub-Total					
10	Supplying of Cables (MARKET ITEM)					
10.1	Supplying of following size ISI marked PVC insulated and PVC sheathed aluminium grade with armored as required.(Make:Finolex,Gloster and Polycab)					
10.1.1	4x16 sq mm	45.00	Metre			
10.1.2	2x16sq mm	42.00	metre			
10.2	Supplying and fixing of following size ISI marked PVC insulated and PVC unsheathed copper single core and multi-core sheathed bright annealed bare copper flexible cables for voltage grade 1.1 KV grade as required.(Make:Finolex,Gloster,Havells and Polycab)					
10.2.1	3x1.5 sqmm	7.00	metre			
10.2.2	3x6.0 sqmm	6.00	metre			
10.2.3	4x6.0sqmm	10.00	metre			
	Sub-Total					
11	Supply of Light Fixtures with Lamps (MARKET ITEM)					
11.1	Supply and fixing of industrial batten suitable for TL5 lamp 28w. Available with optional reflector. (Make: Bajaj, Crompton Greaves, & philips etc) (with 2 years manufacturer's warranty)					
11.1.1	TMSI 22 M 1 X TL5 -28W EBT	8.00	each			
11.1.2	TMS 122 M 2xTL5-28W EBT + GMS 122 228R with Tube	16.00	each			
11.2	Supply and fixing of indoor decorative LED fitting of high efficiency luminaire range suitable for recessed/surface mounting in modular ceiling with 600 x 600/300X300/round type module and extremely low height of 50 mm. (Make: Crompton Greaves, philips etc)					
11.2.1	2X2 Sereno LED TUBE Light fitting with tubes.	8.00	each			
11.3	Repairing of light fittings/Machins.					
11.3.1	Labour charges for dismantling of all electrical items and handover to EMC etc as required.	1.00	Ls			

ITEM No	SUB-HEADS AND ITEM OF WORK	QUANTITY	UNIT	RATE (Rs)	RATE (In Words)	AMOUNT(Rs)
11.4	Supplying and fixing street light luminaire with die cast aluminum housing and toughened glass cover with min IP65 protection , with the LED Type fixtures of following Wattage complete with all accessories and drivers, LN6 heat sink minimum 5kVA surge protection low power LEDs with driving current less than 350mA etc. on existing brackets on street light poles including connection & loop earthing with 3 core 1.5 sqmm flexible PVC insulated PVC round sheathed copper conductor cable from street light box to fitting, testing and commissioning etc. as required. (With 5 years manufacturer's warranty) (Make: Havells, Bajaj, Crompton Greaves, & Philips etc.)					
11.4.1	LED 40W ST white color lamp.	3.00	each			
	Sub-Total					
12	Adaptor box (MARKET ITEM)					
12.1	Cable adaptor box (MARKET ITEM)					
12.1.1	Supplying and fixing of M.S Box of following size with painting with red acid and enamel paint coating as required suitable for outdoor.(Size 300x250x150 mm)	3.00	each			
	Sub-Total					
	Total					